

CERTIFICATE OF COMPLIANCE

Certificate Number 20121115-E161818
Report Reference E161818-20110718
Issue Date 2012-NOVEMBER-15

Issued to: R STAHL SCHALTGERAETE GMBH
AM BAHNHOF 30
74638 WALDENBURG GERMANY

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES FOR USE IN
HAZARDOUS LOCATIONS, AUDIBLE-SIGNAL
APPLIANCES, FIRE ALARM, FOR USE IN
HAZARDOUS LOCATIONS

See Addendum Page for models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 50, 12th Edition, Enclosures for Electrical Equipment, Non-
Environmental Considerations, UL 50E, 1st Edition, UL Standard for
Enclosures for Electrical Equipment, Environmental Considerations ,
CSA 22.2 No. 94.1-07, Enclosures for Electrical Equipment, Non-
Environmental Considerations - First Edition, CSA 22.2 No. 94.2-07,
Enclosures for Electrical Equipment, Environmental Considerations -
First Edition


Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as
being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US
and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and
"US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL;
and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus




CERTIFICATE OF COMPLIANCE

Certificate Number 20121115-E161818
Report Reference E161818-20110718
Issue Date 2012-NOVEMBER-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Class I, Div. 2, Groups A, B, C, and D Hazardous Locations

Audible signal appliance for fire alarm service – Public Mode, YA11 Yodalex series, Model No. YA11, followed by a slash, followed by 1, followed by D, followed by a number from 1 to 32, followed by RN. Intended for indoor and outdoor use



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

