

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E182378  
**Report Reference** E182378-20170210  
**Issue Date** 2019-DECEMBER-16

**Issued to:** R. STAHL Schaltgeraete GmbH  
Am Bahnhof 30  
74638 Waldenburg GERMANY

**This certificate confirms that  
representative samples of**

COMPONENT - AUXILIARY DEVICES FOR USE IN ZONE  
CLASSIFIED HAZARDOUS LOCATIONS  
SEE ADDENDUM PAGE FOR MODELS

Have been investigated by UL in accordance with the  
component requirements in the Standard(s) indicated on  
this Certificate. UL Recognized components are incomplete  
in certain constructional features or restricted in  
performance capabilities and are intended for installation in  
complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:** SEE ADDENDUM PAGE FOR STANDARDS  
**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** E182378  
**Report Reference** E182378-20170210  
**Issue Date** 2019-DECEMBER-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USR– Actuators - front panel mounted to enclosures,

Class I, Zone 1, AEx eb IIC Gb  
Zone 21, AEX tb IIIC Db

CNR – Actuators - front panel mounted to enclosures

Class I, Zone 1, Ex eb IIC Gb U  
Zone 21, Ex tb IIIC Db U

Cat. no. 8602\*3-001-\*, 8602\*3-054-\*, 8602\*3-010-\*, 8602\*3-009-\*, 8602\*3-731-\*, 8602\*3-732-\*, 8602\*3-734-\*, 8602\*3-736-\*, 8602\*3-737-\*, 8602\*3-015-\*, 8602\*3-023-\*, 8602\*3-004-\*, 8602\*3-092-\*, 8602\*3-726-\*, 8602\*3-727-\*, 8602\*3-014-\*, 8602\*3-008-\*, 8602\*3-733-\*, 8602\*3-735-\*, 8602\*3-751-\*, 8602\*3-752-\*, 8602\*3-753-\*, 8602\*3-754-\*, 8602\*3-755-\*, 8602\*3-756-\*, 8602\*3-758-\*, 8602\*3-006-\*, 8602\*3-012-\*, 8602\*3-003-\*, 8602\*3-703-\*, 8602\*3-729-\*, 8602\*3-730-\*, 8602\*3-728-\*, 8602\*3-712-\*

Standard No. UL 508 STANDARD FOR INDUSTRIAL CONTROL EQUIPMENT- Edition 18 - Revision  
Date 2018/03/30

Standard No. CSA C22.2 NO. 14-18 INDUSTRIAL CONTROL EQUIPMENT- Edition 13 - Issue Date  
2018/03/01

Standard No. UL 60079-0 - Electrical Apparatus for Explosive Gas Atmospheres – Part 0: General  
Requirements. Seventh Edition, Issued 2019-03-26


Standard No. UL 60079-7 - Electrical Apparatus for Explosive Gas Atmospheres - Part 7: Increased  
Safety “e”, Fifth Edition, Rev. 2017-04-21

Standard No. UL 60079-31 EXPLOSIVE ATMOSPHERES - PART 31: EQUIPMENT DUST IGNITION  
PROTECTION BY ENCLOSURE “T”- Edition 2 - Issue Date 2015/06/12

Standard No. CAN/CSA C22.2 No. 60079-0:19, Issued 2019-02, Electrical Apparatus for Explosive  
Atmospheres Part 0: General Requirements

Standard No. CAN/CSAC 22.2 No. 60079-7:16, Issued 2016-10, Electrical Apparatus for Explosive  
Atmospheres Part 7: Increased safety “e”

Standard No. CAN/CSA C22.2 NO. 60079-31:15 EXPLOSIVE ATMOSPHERES - PART 31:  
EQUIPMENT DUST IGNITION PROTECTION BY ENCLOSURE “T” - Issue Date 2015/01/01



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

