

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM21CA0045X
3. **Component:** Series 8571/21. SolConeX Receptacle
(Type Reference and Name)
4. **Name of Listing Company:** R STAHL Schaltgeräte GmbH
5. **Address of Listing Company:** Am Bahnhof 30
74638 Waldenburg
GERMANY
6. The examination and test results are recorded in confidential report number:

PR459573 dated 16th September 2021
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA C22.2 No. 60079-0:2019, CSA C22.2 No. 60079-1:2016, CSA C22.2 No. 60079-7:2016,
CSA C22.2 No. 60079-31:2015, CSA C22.2 No. 14:2018, CSA C22.2 No. 25:2017,
CSA C22.2 No. 94.1:2015, CSA C22.2 No. 94.2:2020, CSA C22.2 No. 60947-7-1:2017,
and CSA C22.2 No. 213:2017
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

20 January 2022

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com



SCHEDULE



Canadian Certificate of Conformity No: FM21CA0045X

10. Equipment Ratings:

Series 8571/21:

Ex db eb IIC T6...T5 Gb Ta = -50 °C to +65 °C

Ex tb IIIC T76°C Db Ta = -50°C to +65°C

Class I, Division 2, Groups A, B, C, D, T6...T5 Ta = -50 °C to +65 °C

Class II-III, Division 1, Groups E, F, G, T6...T5 Ta = -50 °C to +65 °C

Type 3, 4, 4X

Ambient temperature rating – Although the standard ambient temperature range marking for the product is -50 °C ≤ T_A < +65 °C, it may be further restricted as follows:

-5 °C ≤ T_A < +40 °C

When DP-E4 EP blanking elements are employed.

-50 °C ≤ T_A < +60 °C

When adhesive-attached metal nameplates are employed.

-50 °C ≤ T_A < +60 °C

When auxiliary contact terminal block is employed.

The application of the product at a particular current with a desired temperature class of either T5 or T6, may further limit the maximum ambient temperature in which the product can be applied. Full details on establishing the maximum ambient are included in the instructions.

11. The marking of the equipment shall include:

Hazardous location ratings per Section 12

Ambient temperature rating

Manufacturer's name and address

Type number

Date Code

Electrical ratings

12. **Description of Equipment:**

The Series 8571/21 Receptacle is intended only for connection to the Series 8571/22 Plug. The Series 8571/21 Receptacle is available with 4 and 5 Pole constructions with rated voltages up to 600 VAC, and ratings up to 30 A and 25 hp. Auxiliary contact blocks 85 708 05 76 0 and 85 708 06 76 0 have an A600 control circuit rating. Contact blocks 85 708 07 76 0 and 85 708 08 76 0 are suitable for use as "Simple Apparatus" in Intrinsically Safe Circuits.

8571/21-a. SolConeX Receptacle.

Ex db eb / IIC / T6...T5 / Gb Ta = -50°C to +65°C

Ex tb IIIC / T76°C / Db Ta = -50°C to +65°C

IPA / I / 2 / ABCD / T6...T5 Ta = -50°C to +65°C

DIP / II,III / 1 / EFG / T6...T5 Ta = -50°C to +65°C

Type 3, 4, 4X

85 708 05 76 0. Optional Auxiliary contact block NC

85 708 06 76 0. Optional Auxiliary contact block NO

85 708 07 76 0. Optional Auxiliary contact block NC for I.S. circuit

85 708 08 76 0. Optional Auxiliary contact block NO for I.S. circuit

a = Configuration 405, 406, 407, 409, 410, 411, 502, 503, 504, 505, 506, 507, 509, 510, and 511.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate of Conformity No: FM21CA0045X

Ambient temperature rating – Although the standard ambient temperature range marking for the product is $-50\text{ }^{\circ}\text{C} \leq T_A < +65\text{ }^{\circ}\text{C}$, it may be further restricted as follows:

- | | |
|--|---|
| $-5\text{ }^{\circ}\text{C} \leq T_A < +40\text{ }^{\circ}\text{C}$ | When DP-E4 EP blanking elements are employed. |
| $-50\text{ }^{\circ}\text{C} \leq T_A < +60\text{ }^{\circ}\text{C}$ | When adhesive-attached metal nameplates are employed. |
| $-50\text{ }^{\circ}\text{C} \leq T_A < +60\text{ }^{\circ}\text{C}$ | When auxiliary contact terminal block is employed. |

The application of the product at a particular current with a desired temperature class of either T5 or T6, may further limit the maximum ambient temperature in which the product can be applied. Full details on establishing the maximum ambient are included in the instructions.

13. Specific Conditions of Use:

1. The receptacle shall not be applied in an explosive dust atmosphere where high electrostatic charging processes are present that could result in propagating brush discharges. See IEC TS60079-32-1 for additional guidance.
2. The Receptacle protective cap shall be tight when plug is not inserted.
3. Receptacle is suitable for connection to a 8571/22 plug of the same configuration and electrical ratings.
4. The flameproof joints cannot be repaired.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
16 th September 2021	Original Issue.
20 th January 2022	Supplement 01: Report Reference:RR231212 dated 20 th January 2022. Description of the Change: Revisions to 5-Pole bayonet ring and flap cover

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com