

CERTIFICATE OF COMPLIANCE

Certificate Number 20141030-E177642
Report Reference E177642-20110103
Issue Date 2014-OCTOBER-30

Issued to: R STAHL SCHALTGERAETE GMBH
AM BAHNHOF 30
74638 WALDENBURG GERMANY

**This is to certify that
representative samples of**

COMPONENT - OUTLET AND JUNCTION BOXES FOR
USE IN ZONE CLASSIFIED HAZARDOUS LOCATIONS
USR Series 8150/0 empty enclosures for use in Hazardous
Location.

Class I, Zone 1, AEx e IIC Gb, Zone 21, AEx tb IIIC Db
CNR Series 8150/0 empty enclosures for use Hazardous
Location.,Ex e IIC Gb U

Class II, Division 2, Groups F and G

Type 8150/0 followed by -0100 to -0800, followed by -0100
to -1020, followed by -060 to -500, followed by -2 or 3,
followed by 3 or 4, followed by 1 or 2, followed by 1.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141030-E177642
Report Reference E177642-20110103
Issue Date 2014-OCTOBER-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard No. UL 50, Enclosures for Electrical Equipment, Non-Environmental Considerations
Standard No. UL 50E, Enclosures for Electrical Equipment, Environmental Considerations
Standard No. CAN/CSA C22.2 No. 94.1-07, Enclosures for Electrical Equipment, Non-Environmental Considerations
Standard No. CAN/CSA C22.2 No. 94.2-07, Enclosures for Electrical Equipment, Environmental Considerations
Standard No. UL 60079-0, Explosive atmospheres - Part 0: Equipment - General Requirements
Standard No. UL 60079-7, Explosive Atmospheres - Part 7: Equipment protection by increased safety "e"
Standard No. ISA 60079-31, Explosive atmospheres - Part 31: Equipment Dust Ignition Protection by Enclosure "t"
CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres - Part 0: Equipment - General Requirements
CAN/CSA-C22.2 No.60079-7:12, Explosive Atmospheres - Part 7: Equipment protection by increased safety "e"
CAN/CSA-C22.2 No. 60079-31:12, Explosive atmospheres -- Part 31: Equipment dust ignition protection by enclosure "t"



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

