

CERTIFICATE

(1) EU-Type Examination

(2) **Equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **DEKRA 12ATEX0232 X** Issue Number: **3**

(4) Product: **Digital Output Module (DOM) Type 9475/3*-**-****

(5) Manufacturer: **R. STAHL Schaltgeräte GmbH**

(6) Address: **Am Bahnhof 30, 74638 Waldenburg, Germany**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/DEK/ExTR12.0069/02.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0 : 2018

EN 60079-7 : 2015 + A1 : 2018

EN 60079-11 : 2012

except in respect of those requirements listed at item 18 of the Schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

(12) The marking of the product shall include the following:



Type 9475/32-**-e* (with e = 1 - 6):
II 2 (1) G Ex ia [ia Ga] IIC T4 Gb and
II (1) D [Ex ia Da] IIIC

Type 9475/33-**-e* (with e = 1 - 6):
II 3 (1) G Ex ec ia [ia Ga] IIC T4 Gc and
II (1) D [Ex ia Da] IIIC

Type 9475/32-**-e* (with e = 1 - 7):
II 2 (2) G Ex ia [ib Gb] IIC T4 Gb and
II (2) D [Ex ib Db] IIIC

Type 9475/33-**-e* (with e = 1 - 7):
II 3 (2) G Ex ec ia [ib Gb] IIC T4 Gc and
II (2) D [Ex ib Db] IIIC

Date of certification: 19 May 2020

DEKRA Certification B.V.

R. Schuller
Certification Manager



(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

(15) **Description**

Digital Output Module (DOM) Type 9475/3*-**-**, for operation in the Remote I/O Systems IS1 and IS1+.

The module is connected to the system via a Bus Rail and it provides up to eight intrinsically safe output circuits for connection of passive, galvanically isolated and unearthed actuators like solenoid, piezo and booster valves. Optionally the Digital Output Module is equipped with an active and a passive Plant-STOP Input to switch off all digital outputs at once.

The intrinsically safe output and input circuits are infallibly galvanically isolated from the IS1 and IS1+ bus supply and data circuits up to a peak voltage of 60 V.

Module type 9475/32*-**-** is intrinsically safe and can be installed in an explosive gas atmosphere requiring equipment of category 2 G.

Module type 9475/33*-**-** is in type of protection Ex ec and can be installed in an explosive gas atmosphere requiring equipment of category 3 G.

Both types of modules may be installed in an explosive dust atmosphere requiring equipment of category 2 D or 3 D if mounted in a suitable enclosure that meets the requirements of an appropriate, recognized type of protection in accordance with EN IEC 60079-0.

The output circuits of Modules Type 9475/3*-**-e* (with e = 1 - 6) are intrinsically safe Ex ia or Ex ib;

the output circuits of Modules Type 9475/3*-**-7* are intrinsically safe Ex ib.

The enclosure of the module provides a degree of protection IP20 according to EN 60529.

The Digital Output Modules Type 9475/3*-**-** may be disconnected or connected to the IS1 or IS1+ Bus Rail while in operation.

Ambient temperature range:

-40 °C to +75 °C;

-40 °C to +65 °C (upside down installation).

Electrical data

Circuit connecting to the IS1 or IS1+ System:

Power supply (input); Plug to BusRail V101/ Pin 7, 8, 9, 10 (+), Pin 27, 28, 29, 30 (-):
in type of protection intrinsic safety Ex ia IIC, with the following maximum values:

$U_i = 26,2 \text{ V}$.

The circuit is equipped with an internal current limitation that limits the current to 450 mA.

Address- and Databus (communication); Plug to BusRail V101/ Pin: 4 (Bus Red.); 5 (Bus Prim.);
14, 15, 16, 24 (Bank 1-4) ; 1, 11, 21 (Mod. Select):

in type of protection intrinsic safety Ex ia IIC, only for connection to the internal Address- and Databus of the IS1/IS1+ System with the following maximum values:

$U_o = 6,6 \text{ V}$; $I_o = 102 \text{ mA}$; $P_o = 168 \text{ mW}$

$U_i = 6,6 \text{ V}$; $C_i = 0 \text{ nF}$; $L_i = 0 \text{ mH}$

Electronic switch control (input); Plug to BusRail V101/ Pin 18, 19:

in type of protection intrinsic safety Ex ia IIC, with the following maximum values:

$U_o = 26,2 \text{ V}$; $I_o = 5,4 \text{ mA}$.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

Intrinsically safe field circuits:

8-Channel Devices Model 9475/3*-08-**:

X1 – Channel 0 (1+/2-); Channel 1 (3+/4-); up to; Channel 7 (15+/16-)

4 Channel Devices Model 9475/3*-04-**:

X1 – Channel 0 (1+/2-); Channel 1 (5+/6-); Channel 2 (9+/10-); Channel 3 (13+/14-)

The values of L_o and C_o in the following tables are the maximum values for combined inductance and capacitance (including cable inductance and capacitance). The values for L_o and C_o marked in grey are the values determined according to the curves and tables of EN 60079-11, Annex A. These grey marked values may be used for the assessment as per EN 60079-11, clause 10.1.5.2.

The internal capacitance per channel is already taken into account in the L_o and C_o values shown in the tables below. The internal inductance is negligibly small.

Type 9475/3*-04-1*

4 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 19,7$ V, $I_o = 142$ mA, $P_o = 698$ mW (linear source), $C_i = 11$ nF; $L_i = 0$ mH.

Table for IIC							
L_o [mH]	1,3	1,1		0,5	0,2	0,1	0,05
C_o [nF]	99	109		119	149	189	220
Table for IIB / IIIC							
L_o [mH]	7,5	5,0	2,0	0,5	0,2	0,1	0,05
C_o [nF]	669	879	889	889	989	1189	1439

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 19,7$ V, $I_o = 53,8$ mA, $P_o = 617$ mW (trapezoidal characteristic, bent at 11,8 V / 52,7 mA), $C_i = 11$ nF; $L_i = 0$ mH.

Table for IIC							
L_o [mH]	3,1	2,0	0,6	0,5	0,2	0,1	0,05
C_o [nF]	109	109	119	119	149	189	220
Table for IIB / IIIC							
L_o [mH]	27,0	20	10	5,0	0,2	0,1	0,05
C_o [nF]	499	609	869	899	1089	1189	1439

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

Type 9475/3*-04-2*

4 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 25,7 \text{ V}$, $I_o = 110 \text{ mA}$, $P_o = 708 \text{ mW}$ (linear source), $C_i = 7,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	1,45	0,75	0,5	0,37	0,2	0,1	0,05
C_o [nF]	-	56	67	76	93	95	95
Table for IIB / IIIC							
L_o [mH]	10,0	5,0	2,0	1,0	0,5	0,2	0,1
C_o [nF]	323	323	333	393	473	633	783

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 25,7 \text{ V}$, $I_o = 49,5 \text{ mA}$, $P_o = 648 \text{ mW}$ (trapezoidal characteristic, bent at $13,6 \text{ V} / 48,5 \text{ mA}$), $C_i = 7,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	1,5	1,0	0,86	0,5	0,37	0,2	0,1
C_o [nF]	43	51	55	69	76	93	95
Table for IIB / IIIC							
L_o [mH]	24	20	2,0	1,0	0,5	0,2	0,1
C_o [nF]	333	333	343	393	483	633	783

Type 9475/3*-04-3*

4 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 26,0 \text{ V}$, $I_o = 90 \text{ mA}$, $P_o = 585 \text{ mW}$ (linear source), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	2,44	2,2	1,0	0,5	0,38	0,2	0,05
C_o [nF]	-	39	55	71	79	94	94
Table for IIB / IIIC							
L_o [mH]	16	10	2,0	1,0	0,5	0,2	0,1
C_o [nF]	335	335	345	395	475	625	765

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 26,0 \text{ V}$, $I_o = 50,4 \text{ mA}$, $P_o = 508 \text{ mW}$ (trapezoidal characteristic, bent at $10,4 \text{ V} / 49,7 \text{ mA}$), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	3,4	2,4	2,0	1,0	0,5	0,39	0,2
C_o [nF]	35	41	44	57	73	80	94
Table for IIB / IIIC							
L_o [mH]	32	20	1,0	0,5	0,2	0,1	0,05
C_o [nF]	345	345	405	485	635	765	765

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

Type 9475/3*-08-4*

8 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 11,5 \text{ V}$, $I_o = 74,8 \text{ mA}$, $P_o = 216 \text{ mW}$ (linear source), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	7,9	5,0	2,0	1,0	0,5	0,2	0,05
C_o [nF]	285	395	585	735	905	1195	1635
Table for IIB / IIIC							
L_o [mH]	34	20	10	5,0	1,0	0,2	0,02
C_o [nF]	1195	1695	2195	2695	4295	6995	11195

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 11,5 \text{ V}$, $I_o = 39,2 \text{ mA}$, $P_o = 194 \text{ mW}$ (trapezoidal characteristic, bent at $5,1 \text{ V} / 38,4 \text{ mA}$), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	22	10	5,0	2,0	1,0	0,5	0,05
C_o [nF]	155	345	475	635	775	935	1635
Table for IIB / IIIC							
L_o [mH]	100	50	20	5,0	1,0	0,2	0,02
C_o [nF]	565	1295	1895	2895	4395	6995	11195

Type 9475/3*-08-5*

8 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 19,4 \text{ V}$, $I_o = 143 \text{ mA}$, $P_o = 692 \text{ mW}$ (linear source), $C_i = 16,5 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	1,44	1,4	0,65	0,5	0,2	0,1	0,05
C_o [nF]	-	103	113	113	153	183	227
Table for IIB / IIIC							
L_o [mH]	7,5	5,0	2,0	0,5	0,2	0,1	0,02
C_o [nF]	673	883	943	943	1083	1183	1493

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 19,4 \text{ V}$, $I_o = 37,8 \text{ mA}$, $P_o = 506 \text{ mW}$ (trapezoidal characteristic, bent at $14,0 \text{ V} / 36,5 \text{ mA}$), $C_i = 16,5 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	6,3	2,0	0,65	0,5	0,2	0,1	0,05
C_o [nF]	113	113	123	123	153	193	227
Table for IIB / IIIC							
L_o [mH]	58	20	10	5,0	0,2	0,1	0,02
C_o [nF]	363	723	953	963	1083	1283	1493

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

Type 9475/3*-08-6*

8 output circuits in type of protection intrinsic safety Ex ia IIB/IIC, Ex ia IIIC with the following maximum values (per channel):

$U_o = 25,7 \text{ V}$, $I_o = 107 \text{ mA}$, $P_o = 688 \text{ mW}$ (linear source), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	1,57	1,1	1,0	0,9	0,5	0,2	0,1
C_o [nF]	-	49	52	54	69	95	97
Table for IIB / IIIC							
L_o [mH]	11	5,0	1,0	0,5	0,2	0,1	0,05
C_o [nF]	335	335	395	485	635	785	785

in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 25,7 \text{ V}$, $I_o = 26,3 \text{ mA}$, $P_o = 468 \text{ mW}$ (trapezoidal characteristic, bent at $19,1 \text{ V} / 24,9 \text{ mA}$), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC							
L_o [mH]	7,0	5,0	2,0	1,0	0,5	0,2	0,05
C_o [nF]	32	36	49	64	81	97	97
Table for IIB / IIIC							
L_o [mH]	100	50	1,0	0,5	0,2	0,1	0,05
C_o [nF]	245	365	425	505	655	785	785

Type 9475/3*-04-7*

4 output circuits in type of protection intrinsic safety Ex ib IIB/IIC, Ex ib IIIC with the following maximum values (per channel):

$U_o = 15,4 \text{ V}$, $I_o = 115,4 \text{ mA}$, $P_o = 1475 \text{ mW}$ (trapezoidal characteristic, bent at $13,2 \text{ V} / 112,4 \text{ mA}$), $C_i = 33 \text{ nF}$; $L_i = 0 \text{ mH}$.

Allowed external capacitance and inductance for group IIC:

L_o [mH]	0,11	0,1	-	0,05	0,02	0,01
C_o [nF]	257	267	-	337	477	488

When using cables with a maximum line length of 700 m, with a cable inductance of $L_c \leq 1 \mu\text{H/m}$, a cable capacitance of $C_c \leq 200 \text{ pF/m}$ and a cable resistance of $R_c \geq 10,76 \text{ m}\Omega/\text{m}$, the following values for C_o and L_o remain:

L_o [mH]	0,05
C_o [nF]	217

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. 3

Allowed external capacitance and inductance for group IIB and IIIC:

L_o [mH]	2,9	2,0	1,0	0,5	0,05	0,02
C_o [nF]	1467	1767	2367	2667	2767	3157

When using cables with a maximum line length of 2000 m, with a cable inductance of $L_c \leq 1 \mu\text{H/m}$, a cable capacitance of $C_c \leq 200 \text{ pF/m}$ and a cable resistance of $R_c \geq 10,76 \text{ m}\Omega/\text{m}$, the following values for C_o and L_o remain:

L_o [mH]	2,0	1,0	0,5	0,02
C_o [nF]	1667	2367	2667	3967

Plant STOP

Plant-STOP I circuit, connector X3 terminals 1 (+) and 2 (-):

in type of protection intrinsic safety Ex ia IIB/IIIC, Ex ia IIIC with the following maximum values:

$U_o = 5,1 \text{ V}$, $I_o = 0,44 \text{ mA}$, $P_o = 0,50 \text{ mW}$ (linear source), $C_i = 5,2 \text{ nF}$; $L_i = 0 \text{ mH}$.

Table for IIC						
L_o [mH]	100	10	2,0	1,0	0,2	0,01
C_o [nF]	2195	2595	3295	3695	5495	15995
Table for IIB / IIIC						
L_o [mH]	100	10	2,0	1,0	0,2	0,01
C_o [nF]	9995	12995	16995	19995	31995	159995

Plant-STOP II circuit, connector X3 terminals 3 and 4:

in type of protection intrinsic safety Ex ia IIB/IIIC, Ex ia IIIC, for connection of an intrinsically safe circuit, with the following maximum values:

$U_i = 30 \text{ V}$, $R_i = 4940 \Omega$, $C_i = 0 \text{ nF}$; $L_i = 0 \text{ mH}$

The Plant-STOP II circuit at X3 is galvanically isolated from all other intrinsically safe circuits.

Installation instructions

The instructions provided with the equipment shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/DEK/ExTR12.0069/02.

(17) **Specific conditions of use**

When installed in an explosive gas atmosphere:

The Digital Output Module (DOM) Type 9475/3*-**-** shall be placed in an enclosure or cabinet that meets the requirements of an appropriate, recognized type of protection in accordance with EN IEC 60079-0.

It shall be used in an area of not more than pollution degree 2, as defined in IEC 60664-1.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at item (9).

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate DEKRA 12ATEX0232 X**

Issue No. **3**

(19) **Test documentation**

As listed in Report No. NL/DEK/ExTR12.0069/02.

(20) **Certificate history**

Issue 1 - 215708500	Initial certificate
Issue 2 - 215299000	Added new equipment to certificate
Issue 3 - 224190000	Assessed per EN IEC 60079-0 : 2018 and EN 60079-7 : 2015 + A1.