



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEX PTB 06.0090	Page 1 of 4	<u>Certificate history:</u>
Status:	Current	Issue No: 4	Issue 3 (2017-06-02)
Date of Issue:	2021-09-10		Issue 2 (2015-02-25)
			Issue 1 (2012-02-09)
			Issue 0 (2006-10-24)
Applicant:	R. STAHL Schaltgeräte GmbH Am Bahnhof 30 74638 Waldenburg Germany		
Equipment:	Control and distribution panel, type 8146/5***-* and 8146/5-****		
Optional accessory:			
Type of Protection:	"db", "eb", "ia", "ib", "mb", "q", "op pr", "op is", "tb"		
Marking:	Ex db eb ia [ia Ga] ib [ib] mb op pr [op is Ga] q IIC T6, T5, T4, T3 Gb Ex [ia Da] [ib] [op is Da] tb IIC T80 °C, T95 °C, T130 °C, T135 °C Db		

Approved for issue on behalf of the IECEx
Certification Body:

Dr. Ing. Detlev Markus

Position:

**Head of Working Group "Explosion Protection in Energy
Technology"**

Signature:
(for printed version)

Date:

14.09.21

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Physikalisch-Technische Bundesanstalt (PTB)
Bundesallee 100
38116 Braunschweig
Germany





IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 06.0090**

Page 2 of 4

Date of issue: 2021-09-10

Issue No: 4

Manufacturer: **R. STAHL Schaltgeräte GmbH**
Am Bahnhof 30
74638 Waldenburg
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-18:2017 Explosive atmospheres - Part 18: Protection by encapsulation "m"
Edition:4.1

IEC 60079-28:2015 Explosive atmospheres - Part 28: Protection of equipment and transmission systems using optical radiation
Edition:2

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-5:2015 Explosive atmospheres -Part 5: Equipment protection by powder filling "q"
Edition:4.0

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/PTB/ExTR06.0106/03](#)

Quality Assessment Report:

[DE/BVS/QAR10.0002/17](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 06.0090**

Page 3 of 4

Date of issue: 2021-09-10

Issue No: 4

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Description of equipment

The control and distribution panel type 8146/5 consists of a glass fibre reinforced enclosure made of polyester, in the type of protection increased safety "eb" and protected by enclosure "tb". The control and distribution panel is intended to be used for the installation of control, regulating and measuring devices as well as of terminals for intrinsically safe and non-intrinsically safe circuits and can be equipped with actuators and indicating lamps, if required. The enclosure area for intrinsically safe circuits is marked, for example in light blue. The control and distribution panel can be equipped with flanges, if necessary. Several enclosures can be combined with one another. Connection is established via Ex cable entries.

The enclosure and all built-in and add-on components are separately certified according to IECEx scheme.

The composition of the protection symbol will be based on the types of protection of components actually used.

Technical data, Nomenclature and Notes for manufacturing and operation: see Annex

SPECIFIC CONDITIONS OF USE: NO



IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 06.0090**

Page 4 of 4

Date of issue: 2021-09-10

Issue No: 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

- 1) Additional Ex components added to list of components
- 2) Standard update to latest IEC standards
- 3) New Certification Instruction

Annex:

COCA060090-04.pdf



Applicant: R. STAHL Schaltgeräte GmbH
Am Bahnhof 30
74638 Waldenburg
Germany

Electrical Apparatus: Control and Distribution Panel type 8146/5***-* and 8146/5-****

Description

The control and distribution panel type 8146/5 consists of a glass fibre reinforced enclosure made of polyester, in the type of protection increased safety "eb" and protected by enclosure "tb". The control and distribution panel is intended to be used for the installation of control, regulating and measuring devices as well as of terminals for intrinsically safe and non-intrinsically safe circuits and can be equipped with actuators and indicating lamps, if required. The enclosure area for intrinsically safe circuits is marked, for example in light blue. The control and distribution panel can be equipped with flanges, if necessary. Several enclosures can be combined with one another. Connection is established via Ex cable entries.

The enclosure and all built-in and add-on components are separately certified according to IECEx scheme.

The composition of the protection symbol will be based on the types of protection of components actually used.

Nomenclature

814	/	5	*	*	*	-	*
a	/	b	c	d	-	e	

- a Type series
- b Design:
 - 5 – Control and distribution panel
- c Enclosure length x width [mm]:
 - 00 – Combination
 - 03 – 112.5 x 112.5
 - 04 – 170.0 x 112.5
 - 24 – 227.0 x 112.5
 - 05 – 170.0 x 170.0
 - 06 – 227.0 x 170.0
 - 07 – 340.5 x 170.0
 - B7 – 340.5 x 170.0
 - S7 – 340.5 x 170.0
 - 08 – 340.5 x 340.5
 - 09 – 681.5 x 340.5
- d Enclosure height [mm]:
 - 0 – Combination
 - 1 – 91 (Enclosure 76 mm, Cover 15 mm)



- 2 – 131 (Enclosure 76 mm, Cover 55 mm)
- 3 – 150 (Enclosure 135 mm, Cover 15 mm)
- 4 – 171 (Enclosure 76 mm, Cover 95 mm)
- 5 – 190 (Enclosure 135 mm, Cover 55 mm)
- 6 – 230 (Enclosure 135 mm, Cover 95 mm)
- 7 – 104 (Enclosure 76 mm, Cover 28 mm)

e Further information without reference to explosion protection

8146	/	*
a	/	b

a Type series

b Design:

- 5-C*** - customized series product
- 5-E*** - modular construction (enclosure combination)
- 5-K*** - configured control panel
- 5-V*** - Series product such as
 - 5-V11 - Load and Motor Switches
 - 5-V27 - Motor protection circuit breaker
 - 5-V37 - Safety Switches
 - 5-V* - others

Note: For customized control and distribution panels, R. STAHL sometimes defines specific versions with special type code.

Electrical data

Rated voltage*	Max 1100 V AC/DC
Rated current*	Max. 630 A
Rated cross section (conductor)*	Max. 300 mm ²
*) depending on terminal type and Ex components used	

Ambient temperature range

Ambient temperature range dependent on the gasket:

Gasket 1 (D0075) -60 °C to +100 °C

Gasket 2 (D00121) -20 °C to +60 °C

The maximum ambient temperature range depends on the maximum ambient temperatures and the power dissipations of the built-in components and of the temperature class rating.



Ingress protection according to IEC 60079-0, IEC 60079-7 and IEC 60079-31: depends on the assembled Ex components or Ex equipments

The rated values are maximum values, the actual electrical values depend on the electrical equipment incorporated. Within the scope of these maximum permissible values and with due regard to the standards, the manufacturer specifies the final rated values dependent on the system conditions, mode of operation, utilization category, etc. The characteristic values of the intrinsically safe circuits are to be given by the manufacturer on his own responsibility.

The maximum permissible ambient temperature range of the control and distribution panel can be limited by the maximum permissible service temperature ranges of the separately certified components.

The composition of the type of protection marking will be based on the types of protection of components actually used.

Notes for manufacturing and operation

Components attached or installed have to be of a technical standard that complies with the specifications on the cover sheet. They must be suited for the operating conditions, and have a separate examination certificate. The special conditions specified for the components must be complied with and may have to be included in the type test. This also applies to components already specified in the technical description.

In order to ensure the ingress protection IP, the cover of the empty enclosure, the flange enclosure, the sealing frame and other Ex-components must be properly installed and with the appropriate torque.

Equipment of the type of protection intrinsic safety "i" is to be installed in such a way that the distances, creepage distances and clearances between intrinsically safe circuits and non-intrinsically safe circuits comply with the requirements of IEC 60079-11.

When more than one intrinsically safe circuit is used, the rules for interconnection are to be observed.

When components are installed into the empty enclosure, clearance and creepage distances specified in the standard IEC 60079-7 and IEC 60079-11 shall duly be complied with.

The control and distribution panel with a coating of polyester powder must not be used in areas affected by charge-producing processes, mechanical friction and separation processes, electron emission (e.g. in the vicinity of electrostatic coating equipment), and pneumatically conveyed dust.