

CERTIFICATE OF COMPLIANCE

Certificate Number E177642
Report Reference E177642-19970509
Issue Date 2020-JULY-06

Issued to: R. STAHL Schaltgeraete GmbH
Am Bahnhof 30
74638 Waldenburg GERMANY

**This certificate confirms that
representative samples of**

OUTLET AND JUNCTION BOXES FOR USE IN ZONE
CLASSIFIED HAZARDOUS LOCATIONS; OUTLET AND
JUNCTION BOXES FOR USE IN HAZARDOUS
LOCATIONS

Series 8146/1 junction boxes for use in Class I, Zone 1,
AEx e IIC T6 Gb and Ex e IIC T6 Gb Hazardous Locations.

Series 8146/1 junction boxes for use in Class II, Division
2, Groups F and G; and Class III hazardous locations.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:
Additional Information:

See Addendum Page
See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E177642
Report Reference E177642-19970509
Issue Date 2020-JULY-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety:

UL 508 and CAN/CSA C22.2 No. 14-05, Industrial Control Equipment

UL 50 and CSA C22.2 NO. 94.1-15, ENCLOSURES FOR ELECTRICAL EQUIPMENT, NON-ENVIRONMENTAL CONSIDERATIONS

UL 50E and CSA C22.2 NO. 94.2-15, ENCLOSURES FOR ELECTRICAL EQUIPMENT, ENVIRONMENTAL CONSIDERATIONS

UL 60079-0 and CAN/CSA E60079-0:11, Electrical Apparatus for Explosive Gas Atmospheres - Part 0: General Requirements

UL 60079-7 and CAN/CSA E60079-7:12, Electrical Apparatus for Explosive Gas Atmospheres - Part 7: Increased Safety "e"

UL 121201 and CSA C22.2 NO. 213, NONINCENDIVE ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II, DIVISION 2 AND CLASS III, DIVISIONS 1 AND 2 HAZARDOUS (CLASSIFIED) LOCATIONS



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

